Ref. Certif. No.

SG ITS-39924

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Battery System
Name and address of the applicant	SURRETTE BATTERY COMPANY LTD 58 LISGAR ST SPRINGHILL, NOVA SCOTIA, BOM 1X0, CANADA.
Name and address of the manufacturer	
Name and address of the factory Note: *When more than one factory, please report on page 2*	
Ratings and principal characteristics	Model S48-100LFP STACK-LV: 51.2V, 100Ah, 5.12kWh Model S48-200LFP STACK-LV: 51.2V, 200Ah, 10.24kWh Model S48-300LFP STACK-LV: 51.2V, 300Ah, 15.36kWh Model S48-400LFP STACK-LV: 51.2V, 400Ah, 20.48kWh Model S48-500LFP STACK-LV: 51.2V, 500Ah, 25.60kWh Model S48-600LFP STACK-LV: 51.2V, 600Ah, 30.72kWh Model S48-700LFP STACK-LV: 51.2V, 700Ah, 35.84kWh Model S48-800LFP STACK-LV: 51.2V, 800Ah, 40.96kWh
Trademark (if any)	Rolls
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	S48-100LFP STACK-LV, S48-200LFP STACK-LV, S48-300LFP STACK-LV, S48-400LFP STACK-LV, S48-500LFP STACK-LV, S48-600LFP STACK-LV, S48-700LFP STACK-LV, S48-800LFP STACK-LV
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 62619:2022
As shown in the Test Report Ref. No. which forms part of this Certificate	250609056GZC-001

This CB Test Certificate is issued by the National Certification Body

Intertek Testing Services (Singapore) Pte Ltd
5, Pereira Road, #06-01
Asiawide Industrial Building
Singapore 368025

intertek

Date: 10 July 2025

Signature:

Ong Keng Chuan